

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PHEE/SM/TB-2/2026-27/ 992

Dated: 06/07/2026

It is certified that an inspection team headed by Salma Ara Ahmed (Laboratory Assistant) from District Level Laboratory (PHED), Sibsagar, PHED inspected the Pakshalika High on 24th April, 2026 and on the basis of Water Test Report (Attached) bearing no TC-1315126000000232F(P) dated 28th April, 2026, of District Level Laboratory (PHED), Sibsagar, (PHED Lab) certified that the Pakshalika High has safe drinking water facilities for the students and members of staff of the institution. The School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till NA

Signature with Seal:

Name : DIPANKAR BORAH

Designation : EXECUTIVE ENGINEER

Name & Address of the Office / Department:

O/o The Executive Engineer (PHED)

District Level Laboratory (PHED), Sibsagar

Sivasagar Division, Sivasagar

To
The Manager,

PAKSHALIKA HIGH
CHAULKORA, SIVSAGAR,
ASSAM

PAKSHALIKA HIGH
Prjanta Borah
Manager



Laboratory Name: District Level Laboratory (PHED), Sivasagar
Office of the Executive Engineer (PHE), Sivasagar Division: Sivasagar
M.I. Borah Road, Jengonikotia, Sivasagar, Assam

CHEMICAL ANALYSIS TEST REPORT

Test Report Number: DLL/SIV/TR/26/0232

Sample ID: DLL/SIV/26-27/04/0232



TC. 13151

ULR ID: TC-13151260000232F(P)
Issued To: PAKSHALIKA HIGH
Dated: 04-28-2026
Customer Reference No.: NULL
Sample received on dated: 04-24-2026
Sample Location: G.P.: KONWARPUR, VILL: 1 NO CHAULKORA
Sample Type: FILTER WATER
Sample collected on dated: 04-24-2026

Issue Date: 04-28-2026
Temperature °C: 24
Humidity %: 65
Sample Description: CLEAR
Sample Quantity: 1L
Date of completion of analysis: 04-28-2026
Sample Collected by: PRIYANKA B. DUTTA
Date of Analysis started: 04-24-2026

RESULTS						
Sr. No.	Parameter	Protocol Used	Unit	IS: 10500:2012 (Second Revision)		Results
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	pH	IS: 3025: Part 11: 2022	pH Units	6.5 - 8.5 @25±2 ^o c	No relaxation	7.15
2	Total Dissolved Solids	IS: 3025: Part 16: 2023	mg/L	500	2000	74
3	Turbidity	IS: 3025: Part 10: 2023	NTU	1	5	2.4
4	Iron	APHA 24 th Ed.-3500- Fe: Method B: 2023	mg/L	1.0	No relaxation	0.612
5	Nitrate	APHA 24 th Ed.-4500-NO ₃ : Method B: 2023	mg/L	45	No relaxation	5.98
6	Chloride	APHA 24 th Ed.-4500-Cl: Method B: 2023	mg/L	250	1000	18.95
7	Total Hardness	APHA 24 th Ed.-2340: Method C: 2023	mg/L	200	600	74.48
8	Total Alkalinity	IS: 3025: Part 23: 2023	mg/L	200	600	74
9	Fluoride	APHA 24 th Ed.-4500-F: Method C: 2023	mg/L	1.0	1.5	0.628
10	Sulphate	IS:3025: Part 24/SEC1: 2023	mg/L	200	400	16.07
11	Arsenic	APHA 24 th Ed.-3500- As: Method B: 2023	mg/L	0.01	No relaxation	BDL
12	Colour	APHA 24 th Ed.-2120: Method B: 2023	Hazen	5	15	5
13	Odour	IS: 3025: Part 6: 2022		Agreeable	Agreeable	AGREEABLE
14	Taste	IS: 3025: Part 8: 2023		Agreeable	Agreeable	AGREEABLE
15	Calcium	APHA 24 th Ed.-3500-Ca: Method B: 2023	mg/L	75	200	9.42
16	Magnesium	APHA 24 th Ed.-3500-Mg: Method B: 2023	mg/L	30	100	15.80
17	Residual Chlorine	IS 3025 Part 26: 2021	mg/L	0.2	1	N/A
18	Conductivity	APHA 24 th Edition-2510 Method B (Electrometric Method), 2023	µS/cm	800	2500	126.4

*BDL- Below Detection Limit for Arsenic <0.009 mg/L, Fluoride <0.1 mg/L, Iron <0.1 mg/L, Magnesium <1 mg/L

Notes:

- The results given above are related to the sample as received and tested in this laboratory. Reliability of sample lies with the sender.
- The test report cannot be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report cannot be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed of after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

K. R. Bordoloi
Kalpajit Bordoloi
Tested by
DLL SIVASAGAR (PHED)

Dr. Banani Deba
Authorized Signatory
(Reviewed and Authorized by)
DLL SIVASAGAR (PHED)

End Report

DISTRICT LEVEL LABORATORY (PHED), SIVASAGAR				
Doc. No : PHE/SIV/QF-7-8 Test Report (Based on ISO/IEC 17025:2017)				
Issue No. 01	Issue Date. 17-10-2022	Amend No. 02	Amend Date: 22-01-2026	Page No.: 1 of 1

PAKSHALIKA HIGH
Manager



Laboratory Name: District Level Laboratory (PHED), Sibsagar
Office of the Executive Engineer (PHE), Sivasagar Division: Sivasagar
A. Borah Road, Jengonikotia, Sivasagar, Assam

MICROBIOLOGY ANALYSIS TEST REPORT



Test Report Number: DLL/SIV/TR/26/0232

Sample ID: DLL/SIV/26-27/04/0232

ULR ID: TC-13151260000232F(P)
Issued To: PAKSHALIKA HIGH
Dated: 04-28-2026
Customer Reference No: NIL
Sample received on dated: 04-24-2026
Sample Location: G.P: KONWARPUR, VILL: 1 NO CHAULKORA
Sample Type: FILTER WATER
Sample collected on dated: 04-24-2026

Issue Date: 04-28-2026
Temperature °C: 24
Humidity %: 65
Sample Description: CLEAR
Sample Quantity: 1L
Date of completion of analysis: 04-28-2026
Sample Collected by: PRIYANKA B. DUTTA
Date of Analysis started: 04-24-2026

Sr. No	Parameter	Protocol Used	Unit	RESULTS		
				Desirable limit	Max. Permissible limit (in absence better alternate source)	Results
1.	Total Coliform	APHA 922B 7 D (24 th Ed., 2023)	CFU/100 ml.	0	0	0
2.	Total E. coli		CFU / 100ml	0	0	0

Notes:

1. The results given above are related to the sample as received and tested in this laboratory. Reliability of sample lies with the sender.
2. The test report cannot be regenerated/re-produced in whole or in part without written permission of Laboratory.
3. The test report cannot be used for any publicity or any legal purpose.
4. The test samples meant for chemical analysis will be disposed of after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Dr. Banani Deka
Authorized Signatory
(Tested, Reviewed and Authorized by)
DLL SIVASAGAR (PHED)

DISTRICT LEVEL LABORATORY (PHED), SIBSAGAR			
Doc. No : PHE/SIV/QF-7-8 Test Report (Based on ISO/IEC 17025:2017)			
Issue No. 01	Issue Date. 17-10-2022	Amend No. 02	Amend Date: 22-01-2026
			Page No.: 1 of 1

PAKSHALIKA HIGH
Priyanka B. Dutta
Manager

